

# Water Quality Report

## Regulatory Parameters

Dec 2021

06/12/2021 to 02/01/2022



- Results -

Monthly  
Average

Monthly  
Maximum

12 Month  
Result #

### BAIRNSDALE

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	6
Total Trihalomethanes	mg/L	1
Turbidity	NTU	6

0	0	0
0.031	0.031	0.039
0.1	0.1	0.2

### BEMM RIVER

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

0	0	0
0.039	0.039	0.066
0.2	0.2	1.5

### BUCHAN

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

0	0	0
0.070	0.070	0.070
0.1	0.1	0.2

### CANN RIVER

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

0	0	0
0.065	0.065	0.100
0.1	0.2	

# The Escherichia coli and Total trihalomethane values are a rolling 12 monthly maximum

**DINNER PLAIN**

Parameter: Units: No. of Samples:

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	6
Turbidity	NTU	4

Monthly Average	Monthly Maximum	12 Month Result #
0	0	0
0.1	0.1	0.1

**EAGLE POINT - PAYNESVILLE**

Parameter: Units: No. of Samples:

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

Monthly Average	Monthly Maximum	12 Month Result #
0	0	0
0.041	0.041	0.045
0.1	0.1	0.2

**KALIMNA**

Parameter: Units: No. of Samples:

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

Monthly Average	Monthly Maximum	12 Month Result #
0	0	0
0.045	0.045	0.052
0.1	0.1	0.1

**LINDENOW**

Parameter: Units: No. of Samples:

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

Monthly Average	Monthly Maximum	12 Month Result #
0	0	0
0.015	0.015	0.030
0.2	0.2	0.2

**LINDENOW SOUTH**

Parameter: Units: No. of Samples:

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

Monthly Average	Monthly Maximum	12 Month Result #
0	0	0
0.028	0.028	0.029
0.1	0.2	0.2

**MALLACOOTA**

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

0	0	0
0.038	0.038	0.170
0.2	0.5	0.6

**MERRANGBAUR**

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

0	0	0
0.051	0.051	0.051
0.1	0.1	0.1

**METUNG**

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

0	0	12
0.028	0.028	0.050
0.1	0.1	0.2

**NICHOLSON - SWAN REACH**

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

0	0	0
0.026	0.026	0.042
0.1	0.2	0.3

**NOWA NOWA**

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

0	0	0
0.053	0.053	0.073
0.2	0.2	0.2

**OME0**

Parameter: Units: No. of Samples:

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

Monthly Average	Monthly Maximum	12 Month Result #
0	0	0
0.053	0.053	0.064
0.1	0.1	0.2

**ORBOST**

Parameter: Units: No. of Samples:

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

Monthly Average	Monthly Maximum	12 Month Result #
0	0	0
0.030	0.030	0.056
0.2	0.3	0.3

**SARFIELD - BRUTHEN**

Parameter: Units: No. of Samples:

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

Monthly Average	Monthly Maximum	12 Month Result #
0	0	0
0.038	0.038	0.047
0.2	0.2	0.2

**SUNLAKES - TOORLOO**

Parameter: Units: No. of Samples:

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	6
Total Trihalomethanes	mg/L	1
Turbidity	NTU	6

Monthly Average	Monthly Maximum	12 Month Result #
0	0	0
0.048	0.048	0.062
0.1	0.1	0.1

**SWIFTS CREEK**

Parameter: Units: No. of Samples:

Parameter:	Units:	No. of Samples:
Escherichia coli	orgs/100mL	4
Total Trihalomethanes	mg/L	1
Turbidity	NTU	4

Monthly Average	Monthly Maximum	12 Month Result #
0	0	0
0.046	0.046	0.057
0.2	0.4	0.5

